

**BOARD OF PUBLIC WORKS
MEMBERS**

GREG GOOD
PRESIDENT

AURA GARCIA
VICE PRESIDENT

DR. MICHAEL R. DAVIS
PRESIDENT PRO TEMPORE

JESSICA M. CALOZA
COMMISSIONER

M. TERESA VILLEGAS
COMMISSIONER

DR. FERNANDO CAMPOS
EXECUTIVE OFFICER

CITY OF LOS ANGELES

CALIFORNIA



ERIC GARCETTI
MAYOR

**DEPARTMENT OF
PUBLIC WORKS**

**BUREAU OF
ENGINEERING**

GARY LEE MOORE, PE, ENV SP
CITY ENGINEER

1149 S. BROADWAY, SUITE 700
LOS ANGELES, CA 90015-2213

<http://eng.lacity.org>

November 8, 2021

John Bianco
Curb-O-Let Products
9421 Monterey Avenue
Bellflower, CA 90706

SUBJECT: CURB-O-LET CURB DRAIN OUTLETS TCD3RD-NS, TCD4RD-NS, TCD35-NS, TCD38-NS, TCD312-NS, TCD317-NS, TCD327-NS, TCD414-NS, TCD422-NS, TCD428-NS BR800048

Dear Mr. Bianco:

The following Curb-O-Let products are approved to use in the City of Los Angeles:

- TCD3RD-NS with a 3" diameter opening
- TCD4RD-NS with a 4" diameter opening
- TCD35-NS with a 3" x 5" opening
- TCD38-NS with a 3" x 8" opening
- TCD312-NS with a 3" x 12" opening
- TCD317-NS with a 3" x 17" opening
- TCD327-NS with a 3" x 27" opening
- TCD414-NS with a 4" x 14" opening
- TCD422-NS with a 4" x 22" opening
- TCD428-NS with a 4" x 28" opening

No more than three Curb-O-Lets, shall be installed, adjacent to each other and there shall be a minimum of 6 inch gap between the edges of the face plates. Please see approved products list for drawing and installation requirements. This approval will expire on November 15, 2023. You may apply for a 2 year extension of this approval 120 days before it expires.


The City assumes no responsibilities for any and all safety related issues in regard to the installation and use of this product. It is the responsibility of the installer to understand the appropriate use and limitations of this product and to address any and all safety concerns with the manufacturer. Further, it is the installer's responsibility to conform to all applicable industry and regulatory safety requirements.

Please be advised that you are required to report any change in the material composition of this product to the City immediately and to recertify this product prior to the expiration of this approval. Any proposed change in product composition, configuration or manufacturing location shall first be approved by this office prior to any fabrication. Changes on already awarded projects will not be allowed.

John Bianco
Curb-O-Let Products – Curb Drain Outlets
October 25, 2021
Page 2 of 2

This approval may be rescinded at any time by the City of Los Angeles at its sole discretion. Please also maintain a copy of this approval for your records and distribute a copy of this approval to the Contractor or other users for use in the field. If you have any questions, please contact Edward Arrington at 213-485-1694 or at Edward.Arrington@lacity.org.

Sincerely,

A handwritten signature in black ink, appearing to read 'E. Arrington', with a large, sweeping flourish extending to the left.

Edward Arrington, S. E., ENV SP
Engineer of Design
Wastewater Conveyance Engineering Division
Bureau of Engineering

Attachment: Product Drawings
cc: Victor Karayan (ConAd – Materials Control)